

ADDENDUM

Project: LDS IF Family History HVAC

Project No.: 504-7137

Addendum No.: 1

Project Address: 750 W. Elva, Idaho Falls, ID 83402

Date: September 25th, 2014

Owner: Corporation of the Presiding Bishop of The Church of Jesus Christ
Of Latter-day Saints, a Utah corporation sole.

From: Engineered Systems Assoc., Inc.

Instructions to Prospective Bidders:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents and/or prior Addenda as noted below. All conditions, requirements, materials and workmanship are to be as described in the Contract Documents unless specifically stated otherwise. This Addendum consists of 3 page(s) and the attached drawing(s), Sheet(s) ME1.1 & ME1.2, dated 9/22/14.

1. Changes Specifications:

- a. Replace Contractor Bid Proposal and Maintenance Agreement with revised proposal attached.

2. Changes to Drawings: Sheets ME1.1 and ME1.2- see revised sheets attached noted Addendum #1.

- a. Furnace F-1 and CU-1 are new and do not need to be replaced.
- b. Condensing unit CU-8 is R-22. Replace existing condensing unit and coiling coil with new under Alternate #2. Existing Lineset may have a leak in this system. Verify lines hold charge and repair as necessary.

End of Addendum