

ASI NO.2

May 5, 2021

PROJECT NAME: Intermountain Meat Packing Interior Finish

This ASI consists of   1   page(s) and   0   page(s) attachment for a total of   1   page(s).

Changes to the Drawings:

1. Sheet M0.2 (Building Shell Drawings)
  - a. Exhaust Fan Schedule – Any 120 V Fractional H.P. Motors marked with Note 2 shall be controllable ECM Motors rather than provided with VFD.
  - b. EF – 26 & 27 shall operate from both temperature and CO2 sensor. Refer to Spec Section 23 0995.

END OF ASI #2